



OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT, CENTRAL LABORATORY
Gandhi Nagar (Near Reserve Bank Quarters), Rajasthan, Jaipur - 302 015
REPORT OF THE BACTERIOLOGICAL EXAMINATION OF WATER

No: Lab/Bact/2020-21/

9458

Dated: 15/01/2021

To
The Principal,
Vidhya Sagar Sr. Sec. School,
Sector-7, Pratap Nagar,
Jaipur (Raj.)


Not valid for Water
Quality Legal Cases

The sample was not collected
by this laboratory.

Reference - Your Application on Dated 04.01.2021
GRN NO. - 46113385 Paid on Date 05.01.2021

Distt: Jaipur
Tehsil: Jaipur
Name of Sample Taker - School Staff


Sample No.	Date of Collection	Date of Examination	Residual Chlorine mg/l	Area	Particulars of Samples	Coliform Organisms MPN/100 ml	E-Coli Organism (MPN)	Remarks (Satisfactory/ Unsatisfactory)
P:30 ----- 3655	05.01.2021	05.01.2021	---	Pratap Nagar Area	T/W, School Campus, Vidhya Sagar Sr. Sec. School, Sector-7, Pratap Nagar, Jaipur	Nil	Nil	Satisfactory


Superintending Chemist
PHED, Laboratory, Jaipur
Dated: 15/01/21


No: Lab/Bact/2020-21/

Copy to:

1. The Chief Chemist, PHED, Rajasthan, Jaipur


अध्यक्ष
श्री श्रीजी शिक्षा समिति
श्रीधर सांगानेर (जयपुर)


PRINCIPAL
Vidhya Sagar Sr. Sec. School
Pratap Naga, Sanganer, JAIPUR
CBSE Aff. No. - 730665


Superintending Chemist
PHED, Laboratory, Jaipur
Dated:

SECRETARY
VIDHYA SAGAR SR. SEC. SCHOOL
70-71, PRATAP NAGAR, SHEOPUR
SANGANER, JAIPUR

OFFICE OF THE CHIEF CHEMIST
PUBLIC HEALTH ENGINEERING DEPARTMENT LABORATORY, GANDHI NAGAR, JAIPUR
REPORT OF THE CHEMICAL EXAMINATION OF WATER

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2020-2021/ 9792

Date: 25-1-21

To,
 The Principal
 Vidhya Sagar Sr.Sec. School
 Pratap Nagar ,Sanganer
 Jaipur.

The Sample was not Collected
 by this Laboratory

Not Valid for water
 quality \ Legal Cases

Date of Receipt: 05.01.2021

Particulars	value as per I.S.:10500/2012		TW Vidhya Sagar Sr. Sec. School
	Requirement (Acceptable Limit)	Permissible Limit in the absence of Alternate Source	Jaipur
Village / Town			
Date of Collection			04.01.2021
Lab. Sample No.			P-37
1. pH	6.5-8.5	6.5-8.5	7.48
2. Turbidity (NTU)	1	5	Nil
3. Colour (Hazen units)	5	15	None
4. Odour	Un Objectionable		U.O
5. Total Alkalinity(as CaCo3) mg/l	200	600	130
6. Total Hardness (as CaCo3) mg/l	200	600	100
7. Calcium (as Ca) mg/l	75	200	24
8. Magnesium (as Mg) mg/l	30	100	10
9. Chloride (as Cl-) mg/l	250	1000	60
10. Nitrates (as NO3-) mg/l	45	45	40
11. Sulphate (as SO4-2) mg/l	200	400	16
12. Total Dissolved Solids mg/l	500	2000	350
13. Fluoride mg/l	1.00	1.5	0.16
14. Iron mg/l	1.0	No Relaxation	Nil
15. Arsenic mg/l	0.01	No Relaxation	Nil

[Signature]
 25/1/21
 Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur

No: Lab/Sup.Chem. (HM) / Jaipur (City) /2020-2021/
 Copy to:-

1.The Chief Chemist, PHED Raj. Jaipur

[Signature]
 अध्यक्ष
 श्री मौजी शिक्षा समिति
 पोपुर सांगानेर (जयपुर)

Superintending Chemist (Heavy Metal)
 P.H.E.D. Laboratory, Jaipur
[Signature]
SECRETARY
 VIDHYA SAGAR SR. SEC. SCHOOL,
 70-71, PRATAP NAGAR, SHEOPUR
 SANGANER, JAIPUR

[Signature]
PRINCIPAL
 Vidhya Sagar Sr. Sec. School
 Pratap Nagar, Sanganer, JAIPUR
 CBSE Aff. No. - 730665