

42

MUNICIPAL CORPORATION OF DELHI
(Office of Dy. Health Officer: Rohini Zone)
Public Health Department
Sector 5 Rohini Delhi -110085
Email: dhoroheinzone15@gmail.com Tel: 011-27052106

No.-DHO/RZ/2023/164

Date : 30/06/2023

SCHOOL HEALTH CERTIFICATE

It is certified that an inspection team headed Asst. Public health Inspector from Public Health department Rohini Zone inspected the CITIZEN MODEL SCHOOL at Budh Vihar, Phase-II, Delhi-110099 and found that the CITIZEN MODEL SCHOOL has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from date of issue.

Dy. Health Officer
Rohini Zone

Deputy Health Officer
Municipal Corporation of Delhi
Rohini Zone

Principal
CITIZEN MODEL SCHOOL
Budh Vihar, Phase-II, Delhi-110099


Mrs. Samita Singla
PRINCIPAL
CITIZEN MODEL SCHOOL
BUDH VIHAR, PHASE-II
DELHI-110.



MICRO ENGINEERING & TESTING LABORATORY

(An ISO 9001:2015 & 14001:2015 Certified Laboratory)

43

Office

I-4, First Floor, Mukund House,
Azadpur, Delhi-110 033
T: 011 46018197 | M: +91 9871143785

Laboratory

Plot No. 43, HSIDC, Indl. Estate,
Rai, Sonapat, Haryana-131029
T: 0130 4017631 | M: +91 9215515882

Email/Website

info@metl.co.in
metlson@yahoo.com
www.metl.co.in

TEST REPORT

ULR No.	71832300000001136	Dated:	29/04/2023
Report No.	METL/23-24/166/0008/51	Service Request Date	15/06/2023
Date of Issue	17/06/2023	Sample Request On	15/06/2023
Customer Name & Address		Sample Details	
CITIZEN MODEL SCHOOL BUDH VIHAR, PHASE-II, DELHI-110099		Description of Sample	Water (for Drinking Purpose)
		Sampling Done by	Customer
		Source	RO
		Sample Protocol	N.A
		Packing	Plastic Bottle
		Sample Location	Citizen Model School
Subject: Request for Drinking Water Testing Reports of the School		Quantity	1 Ltr.
		Analysis Done on	15-16/06/2023

Requirement as per IS: 10500-2012; RA-2018(Drinking Water)

S. No.	Characteristics	Test -Value	Acceptable Limit	Permissible Limit in absence of Alternate Source	Method of Test
1	Colour, Hazen unit. Max.	<5	5	15	IS-3025(P-4)-2021
2	Odour	Agreeable	Agreeable	Agreeable	IS- 3025(P-5)-2018
3	Turbidity, NTU. Max.	0.92	1	5	IS-3025(P-10)-1984; RA-2017
4	pH Value, 25.0 °C	7.10	6.5 – 8.5	No Relaxation	IS-3025(P-11)-2022
5	Total Hardness, (as CaCO ₃), mg/l Max.	124	200	600	IS-3025(P-21)-2009; RA-2019
6	Iron (as Fe), mg/l Max.	0.08	1.0	No Relaxation	IS-3025(P-53)-2003; RA-2019
7	Chloride (as Cl), mg/l Max.	42	250	1000	IS-3025(P-32)-1988; RA-2019
8	*Residual Free Chlorine, mg/l Min.	Nil	0.2	1.0	IS: 3025 (P-26)-1986; RA-2019
9	Fluoride (as F), mg/l Max.	0.11	1.0	1.5	APHA 23 rd Edn. 2017 (Method – 4500 F)
10	Total Dissolved Solids mg/l Max.	222	500	2000	IS-3025(P-16)-2023

Remark: With respect to the above test, water sample conforms IS: 10500-2012; RA-2018.

Note: * To be applicable only when water is chlorinated.

Review by:

Page No. 1/1



Mrs. Sunita Singla
PRINCIPAL
CIT ZEN MODEL SCHOOL
BUDH VIHAR, PHASE-II
DELHI-110

Terms & Conditions

- The result listed refer only to the tested samples and applicable parameters endorsement of product is neither inferred nor implied.
- Total liability of our Lab. is limited to the invoiced amount.
- Samples will be destroyed after 30 Days from the date of issue of test report.
- The report is not be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.





MICRO ENGINEERING & TESTING LABORATORY

(An ISO 9001:2015 & 14001:2015 Certified Laboratory)

Office
I-4, First Floor, Mukund House,
Azadpur, Delhi-110 033
T: 011 48078197 | M: +91 9871143785

Laboratory
Plot No. 43, HSIDC, Indl. Estate,
Ral. Sonapat, Haryana-131029
T: 0130 4017631 | M: +91 9815515852

44
Email/Website
info@metl.co.in
metlson@yahoo.com
www.metl.co.in

TEST REPORT

Report No.	METL/23-24/166/0008/51	Dated:	29/04/2023
Service Request No.	1136	Service Request Date	15/06/2023
Date of Issue	17/06/2023	Sample Request On	15/06/2023
Customer Name & Address		Sample Details	
CITIZEN MODEL SCHOOL BUDH VIHAR, PHASE-II, DELHI-110099		Description of Sample	Water (for Drinking Purpose)
		Sampling Done by	Customer
		Source	RO
		Sample Protocol	N.A
		Packing	Plastic Bottle
		Sample Location	Citizen Model School
		Quantity	1 Ltr.
Subject: Request for Drinking Water Testing Reports of the School		Analysis Done on	15-16/06/2023

Requirement as per IS: 10500-2012; RA-2018 (Drinking Water)

S. No.	Characteristics	Test Value	Acceptable Limit	Method of Test
1	Total Coliforms Organisms, (MPN/100ml)	Absent	Shall not be detectable in 100ml, sample	IS-1622-1981, RA-2019
2	E Coli /100ml	Absent	Shall not be detectable in 100ml, sample	IS-1622-1981, RA-2019

Remark: With respect to the above test, water sample conforms IS: 10500-2012; RA-2018, for Bacteriological Parameters.

Review by:

Mrs. Sunila Singla
PRINCIPAL
CIT ZEN MODEL SCHOOL
BUDH VIHAR, PHASE-II
DELHI-116.

Terms & Conditions
The result listed refer only to the tested samples and applicable parameters endorsement of product is neither inferred nor implied.
Total liability of our Lab. is limited to the invoiced amount.
Samples will be destroyed after 30 Days from the date of issue of test report.
This report is not to be reproduced wholly or in part and cannot be used as an evidence in the court of law and should not be used in any advertising media without our special permission in writing.

